

Field Termination Plug User Guide

FPS

①

Copper Foil Tape
30mm
10mm

②

Boot
Cable

③

30mm Min.
10mm
or
10mm
30mm Min.
S/FTP
U/FTP.F/UTP

④

30mm Min.
10mm
Copper Foil Tape

⑤

30mm Min.
10mm
Wrapped up

⑥

⑦

5-8mm Max.

⑧

⑨

Cut front row wires flush

⑩

Cut rear row wires flush

⑪

0.2mm Max.

⑫

KEY

⑬

1

⑭

2
3

⑮

⑯

Legend

1	2	3	4	5	6	7	8
W-G	G	W-O	BL	W-BL	O	W-BR	BR

Pin assignment T568A

1	2	3	4	5	6	7	8
W-O	O	W-G	BL	W-BL	G	W-BR	BR

Pin assignment T568B

	Solid	Stranded	Cable (O.D.)
C6A	23~26AWG	23~26AWG	6.0~7.5mm
C8	22~24AWG	22~24AWG	7.0~8.5mm