

CERTIFICATE OF CONFORMITY

Product: Mounting boxes, flush-type

Tested by request of Ampi sprl
Z.I. Hannut
rue des Combattants, 45
4280 HANNUT
Belgium

Manufactured at (name and place) Ampi sprl
Z.I. Hannut
rue des Combattants, 45
4280 HANNUT
Belgium

Trade mark (if any): ARPI

Model/Type Ref: 615xx, 615xxN, 616xx, 616xxN

Ratings and principal characteristics: IP64, IK10

Additional information (if any) :

See appended table

A sample of the product has been tested and found to be in conformity with :

EN 60529:1991 + corrigendum May 1993 + A1:2000, IEC 60529:1989 + A1:1999, IEC 62262:2002

as shown in the test reports 590520.01a & 590520.01b

This Certificate of Conformity is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard. It does not imply an assessment of the whole production. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Brussels, 04/01/2016

C. LANA,
Certification Manager.

